

Training Course on the IAEA Safety Standards Overview

IAEA Specific Safety Requirements SSR-2/1 (Rev.1) Safety of Nuclear Power Plants: Design and corresponding guides

Jorge LUIS HERNANDEZ

Safety Assessment Section (SAS)
Division of Nuclear Installation Safety (NSNI)
Department of Nuclear Safety and Security, IAEA


Shinagawa Campus, Tokai University, Tokyo, Japan

04 - 07, August 2026



Outline

- INTRODUCTION
- REV.1 OF IAEA DESIGN SAFETY REQUIREMENTS
- OVERVIEW OF REQUIREMENTS
 - MANAGEMENT OF SAFETY IN DESIGN
 - PRINCIPAL TECHNICAL REQUIREMENTS
 - GENERAL PLANT DESIGN REQUIREMENTS
 - DESIGN OF SPECIFIC PLANT SYSTEMS
- SAFETY GUIDES ON NPP DESIGN
- CONCLUSIONS



Design Safety















Safety objectives and
safety principles



Functional conditions
required for safety



Guidance on how to
fulfil the requirements



Safety approach for the design of NPPs

Safety
Objective

Protect people and the environment from harmful
effects of ionizing radiation

Principles

P5. Optimization of Protection

P6. Limitation of Risks to Individuals


P7. Protection of Present and Future Generations

P8. Prevention of Accidents

P9. Emergency Preparedness and Response

prerequisites

SSR 2/1 (Rev. 1): Safety of Nuclear Power Plants: Design



- **Published in 2016, revised after 2012** to consider the main observations and lessons from the accident at the Fukushima Daiichi Nuclear Power Plant
- The review revealed no significant areas of weakness and resulted in a small set of amendments to strengthen the requirements and facilitate their implementation
- **Requirements applicable to the NPP design** and elaborates on the safety objective, safety principles and concepts that provide the basis for deriving the safety requirements that must be met for the NPP design

*Useful for **wide range of stakeholders**: organizations involved in design, manufacture, construction, modification, maintenance, operation and decommissioning of NPP, as well as for regulatory bodies*

Importance of SSR for NPP Design (1/2)

Define safety approach and establish safety “level” for NPP designs

- reflects the state of the art
- reflects the views and the licensing practices of the majority of IAEA Member States
- based on large consensus

Provide links with requirements for site evaluation and for operation

- taking into consideration impact of site on design
- ensuring safe operation and maintenance of plant

Importance of SSR for NPP Design (2/2)


Requirements collected in this safety standard

- are the main reference to perform IAEA design safety reviews
- significantly contributed to establishing a common safety approach and terminology
- used as reference for establishing licensing regulations in several countries
 - adopted as national regulation
 - used to integrate existing national regulations

SSR 2/1 (Rev. 1): Safety of Nuclear Power Plants: Design (1/5)

Reinforce the application of the **Defence-in-Depth** concept, by implementing independent Defence-in-Depth provisions

Ref. US NRC site - US EPR Final Safety Analysis Report: Severe Accident Evaluation & Reactor Coolant System




SSR 2/1 (Rev. 1): Safety of Nuclear Power Plants: Design (2/5)



Construction 18m embankment to protect against tsunami Hamaoka NPP, Japan

Stressing the need for **sufficient and adequate margins to avoid cliff edge effects.**

For items that ultimately prevent large or early releases, **margins are required also for hazards more severe than those selected for the design basis**



SSR 2/1 (Rev. 1): Safety of Nuclear Power Plants: Design (3/5)



Wolsong NPP, Republic of Korea

Multi-unit site considerations related to the independence of dedicated, to each unit, safety systems for DBA and additional safety features for DEC.

DBA=Design Basis Accidents


DEC=Design Extension Conditions

Reinforced capabilities for heat transfer to the UHS.


UHS=Ultimate Heat Sink



SSR 2/1 (Rev. 1): Safety of Nuclear Power Plants: Design (5/5)



Ref. US NRC site - US EPR Final Safety Analysis
Report: Electrical power distribution



- Implementation of features (design, procedures, etc.) to enable the use of **non permanent equipment**
- Reinforced capabilities for power supply in DEC's
- Additional measures for spent fuel pool instrumentation, cooling and maintaining inventory

A few definitions

- Technology neutral: Not related to a technology (e.g. Requirements 1, 2, 3 of SSR-2/1 (Rev. 1)).
- Technology inclusive: Proposing requirements that aim at encompassing all or a part of the collection of reactor technologies (e.g. Requirements of section Principal Technical Requirements in SSR-2/1 (Rev. 1))
- Technology specific: WCR, HTGR, FNR, MSR (e.g. Requirements of section Design of Specific Plant Systems in SSR-2/1 (Rev. 1))
- Design specific: Related to specific features for a given design. (e.g. Russian PWR (VVER) vs PWR Westinghouse designs)

SSR 2/1 (Rev. 1) : Table of contents (1/2)

IAEA Safety Standards

for protecting people and the environment

Safety of Nuclear Power Plants: Design

Specific Safety Requirements
No. SSR-2/1 (Rev. 1)



CONTENTS	
1. INTRODUCTION	1
Background (1.1–1.3)	1
Objective (1.4–1.5)	2
Scope (1.6–1.8)	2
Structure (1.9)	3
2. APPLYING THE SAFETY PRINCIPLES AND CONCEPTS (2.1–2.5)	3
Radiation protection in design (2.6–2.7)	4
Safety in design (2.8–2.11)	5
The concept of defence in depth (2.12–2.14)	6
Maintaining the integrity of design of the plant throughout the lifetime of the plant (2.15–2.18)	9
3. MANAGEMENT OF SAFETY IN DESIGN	10
Requirement 1: Responsibilities in the management of safety in plant design (3.1)	10
Requirement 2: Management system for plant design (3.2–3.4)	10
Requirement 3: Safety of the plant design throughout the lifetime of the plant (3.5–3.6)	11
4. PRINCIPAL TECHNICAL REQUIREMENTS	12
Requirement 4: Fundamental safety functions (4.1–4.2)	12
Requirement 5: Radiation protection in design (4.3–4.4)	13
Requirement 6: Design for a nuclear power plant (4.5–4.8)	13
Requirement 7: Application of defence in depth (4.9–4.13A)	14
Requirement 8: Interfaces of safety with security and safeguards	16
Requirement 9: Proven engineering practices (4.14–4.16)	16
Requirement 10: Safety assessment (4.17–4.18)	17
Requirement 11: Provision for construction (4.19)	17
Requirement 12: Features to facilitate radioactive waste management and decommissioning (4.20)	17

GENERAL PLANT DESIGN	18
Design basis	18
Requirement 13: Categories of plant states (5.1–5.2)	18
Requirement 14: Design basis for items important to safety (5.3)	19
Requirement 15: Design limits (5.4)	19
Requirement 16: Postulated initiating events (5.5–5.15)	19
Requirement 17: Internal and external hazards (5.15A–5.22)	21
Requirement 18: Engineering design rules (5.23)	23
Requirement 19: Design basis accidents (5.24–5.26)	23
Requirement 20: Design extension conditions (5.27–5.32)	24
Requirement 21: Physical separation and independence of safety systems (5.33)	26
Requirement 22: Safety classification (5.34–5.36)	26
Requirement 23: Reliability of items important to safety (5.37–5.38)	27
Requirement 24: Common cause failures	27
Requirement 25: Single failure criterion (5.39–5.40)	27
Requirement 26: Fail-safe design (5.41)	28
Requirement 27: Support service systems (5.42–5.43)	28
Requirement 28: Operational limits and conditions for safe operation (5.44)	28
Design for safe operation over the lifetime of the plant	29
Requirement 29: Calibration, testing, maintenance, repair, replacement, inspection and monitoring of items important to safety (5.45–5.47)	29
Requirement 30: Qualification of items important to safety (5.48–5.50)	30
Requirement 31: Ageing management (5.51–5.52)	30
Human factors	31
Requirement 32: Design for optimal operator performance (5.53–5.62)	31
Other design considerations	33
Requirement 33: Safety systems, and safety features for design extension conditions, of units of a multiple unit nuclear power plant (5.63)	33
Requirement 34: Systems containing fissile material or radioactive material	33
Requirement 35: Nuclear power plants used for cogeneration of heat and power, heat generation or desalination	33

SSR 2/1 (Rev. 1) : Table of contents (2/2)

IAEA Safety Standards

for protecting people and the environment

Safety of Nuclear Power Plants: Design

Specific Safety Requirements
No. SSR-2/1 (Rev. 1)



Requirement 36: Escape routes from the plant (5.64–5.65)	33	Requirement 59: Provision of instrumentation (6.31)	46
Requirement 37: Communication systems at the plant (5.66–5.67)	34	Requirement 60: Control systems	46
Requirement 38: Control of access to the plant (5.68)	34	Requirement 61: Protection system (6.32–6.33)	46
Requirement 39: Prevention of unauthorized access to, or interference with, items important to safety.	34	Requirement 62: Reliability and testability of instrumentation and control systems (6.34–6.36)	47
Requirement 40: Prevention of harmful interactions of systems important to safety (5.69–5.70)	35	Requirement 63: Use of computer based equipment in systems important to safety (6.37)	48
Requirement 41: Interactions between the electrical power grid and the plant	35	Requirement 64: Separation of protection systems and control systems (6.38)	48
Safety analysis	35	Requirement 65: Control room (6.39–6.40A)	49
Requirement 42: Safety analysis of the plant design (5.71–5.76)	35	Requirement 66: Supplementary control room (6.41)	49
DESIGN OF SPECIFIC PLANT SYSTEMS.	37	Requirement 67: Emergency response facilities on the site (6.42)	50
Reactor core and associated features	37	Emergency power supply.	50
Requirement 43: Performance of fuel elements and assemblies (6.1–6.3)	37	Requirement 68: Design for withstanding the loss of off-site power (6.43–6.45A)	50
Requirement 44: Structural capability of the reactor core	38	Supporting systems and auxiliary systems	52
Requirement 45: Control of the reactor core (6.4–6.6)	38	Requirement 69: Performance of supporting systems and auxiliary systems	52
Requirement 46: Reactor shutdown (6.7–6.12)	39	Requirement 70: Heat transport systems (6.46)	52
Reactor coolant systems	40	Requirement 71: Process sampling systems and post-accident sampling systems (6.47)	52
Requirement 47: Design of reactor coolant systems (6.13–6.16)	40	Requirement 72: Compressed air systems.	52
Requirement 48: Overpressure protection of the reactor coolant pressure boundary.	41	Requirement 73: Air conditioning systems and ventilation systems (6.48–6.49)	53
Requirement 49: Inventory of reactor coolant.	41	Requirement 74: Fire protection systems (6.50–6.54)	53
Requirement 50: Cleanup of reactor coolant (6.17)	41	Requirement 75: Lighting systems	54
Requirement 51: Removal of residual heat from the reactor core.	41	Requirement 76: Overhead lifting equipment (6.55)	54
Requirement 52: Emergency cooling of the reactor core (6.18–6.19)	42	Other power conversion systems	55
Requirement 53: Heat transfer to an ultimate heat sink (6.19A–6.19B)	42	Requirement 77: Steam supply system, feedwater system and turbine generators (6.56–6.58)	55
Containment structure and containment system	43	Treatment of radioactive effluents and radioactive waste	55
Requirement 54: Containment system for the reactor	43	Requirement 78: Systems for treatment and control of waste (6.59–6.60)	55
Requirement 55: Control of radioactive releases from the containment (6.20–6.21)	43	Requirement 79: Systems for treatment and control of effluents (6.61–6.63)	56
Requirement 56: Isolation of the containment (6.22–6.24)	43	Fuel handling and storage systems	56
Requirement 57: Access to the containment (6.25–6.26)	44	Requirement 80: Fuel handling and storage systems (6.64–6.68A)	56
Requirement 58: Control of containment conditions (6.27–6.30)	45	Radiation protection.	59
Instrumentation and control systems	46	Requirement 81: Design for radiation protection (6.69–6.76)	59
		Requirement 82: Means of radiation monitoring (6.77–6.84)	60

Design safety

Management of Safety in Design Requirements

Management of Safety in Design

Requirement 1: Responsibilities in the management of safety in plant design

- **An applicant for a license** to construct and/or operate a nuclear power plant shall be responsible for ensuring that the design submitted to the regulatory body meets all applicable safety requirements.

Requirement 2: Management system for plant design

- The **design organization** shall establish and implement a management system for ensuring that all safety requirements established for the design of the plant are considered and implemented in all phases of the design process and that they are met in the final design.

Management of Safety in Design

Requirement 3: Safety of the plant design throughout the lifetime of the plant

- The **operating organization** shall establish a formal system for ensuring the continuing safety of the plant design throughout the lifetime of the nuclear power plant.
- It shall be ensured that
 - the plant design meets the acceptance criteria for safety, reliability and quality as defined in plant design, and verified during the periodic safety reviews
 - formal system is established for
 - design verification,
 - definition of engineering codes and standards and requirements,
 - use of proven engineering practices,
 - provision for feedback of information on construction and experience,
 - approval of key engineering documents,
 - conduct of safety assessments and maintaining a safety culture

Management of Safety in Design

Requirement 3:

- the knowledge of the design is available and maintained up to date
- management of design requirements and configuration control are maintained
- necessary interfaces with responsible designers and suppliers engaged in design work are established and controlled
- engineering expertise and scientific and technical knowledge are maintained within the operating organization
- design changes to the plant are reviewed, verified, documented and approved
- adequate documentation is maintained to facilitate future decommissioning of the plant

Design safety

Principal Technical Requirements & General plant design

SSR 2/1 (Rev. 1) : Table of contents (2/2)

IAEA Safety Standards
for protecting people and the environment

Safety of Nuclear Power Plants: Design

Specific Safety Requirements
No. SSR-2/1 (Rev. 1)



CONTENTS	
1. INTRODUCTION	1
Background (1.1-1.3)	1
Objective (1.4-1.5)	2
Scope (1.6-1.8)	2
Structure (1.9)	3
2. APPLYING THE SAFETY PRINCIPLES AND CONCEPTS (2.1-2.5)	3
Radiation protection in design (2.6-2.7)	4
Safety in design (2.8-2.11)	5
The concept of defence in depth (2.12-2.14)	5
Maintaining the integrity of design of the plant throughout the lifetime of the plant (2.15-2.18)	9
3. MANAGEMENT OF SAFETY IN DESIGN	10
Requirement 1: Responsibilities in the management of safety in plant design (3.1)	10
Requirement 2: Management system for plant design (2.3-3.4)	10
Requirement 3: Safety of the plant design throughout the lifetime of the plant (3.5-3.6)	11
4. PRINCIPAL TECHNICAL REQUIREMENTS	12
Requirement 4: Fundamental safety functions (4.1-4.2)	12
Requirement 5: Radiation protection in design (4.3-4.4)	13
Requirement 6: Design for a nuclear power plant (4.5-4.8)	13
Requirement 7: Application of defence in depth (4.9-4.13A)	14
Requirement 8: Interfaces of safety with security and safeguards	16
Requirement 9: Proven engineering practices (4.14-4.16)	16
Requirement 10: Safety assessment (4.17-4.18)	17
Requirement 11: Provision for construction (4.19)	17
Requirement 12: Features to facilitate radioactive waste management and decommissioning (4.20)	17

GENERAL PLANT DESIGN	
Design basis	18
Requirement 13: Categories of plant states (5.1-5.2)	18
Requirement 14: Design basis for items important to safety (5.3)	19
Requirement 15: Design limits (5.4)	19
Requirement 16: Postulated initiating events (5.5-5.15)	21
Requirement 17: Internal and external hazards (5.15A-5.22)	21
Requirement 18: Engineering design rules (5.23)	23
Requirement 19: Design basis accidents (5.24-5.26)	23
Requirement 20: Design extension conditions (5.27-5.32)	24
Requirement 21: Physical separation and independence of safety systems (5.33)	26
Requirement 22: Safety classification (5.34-5.36)	26
Requirement 23: Reliability of items important to safety (5.37-5.38)	27
Requirement 24: Common cause failures	27
Requirement 25: Single failure criterion (5.39-5.40)	27
Requirement 26: Fail-safe design (5.41)	28
Requirement 27: Support service systems (5.42-5.43)	28
Requirement 28: Operational limits and conditions for safe operation (5.44)	28
Design for safe operation over the lifetime of the plant	29
Requirement 29: Calibration, testing, maintenance, repair, replacement, inspection and monitoring of items important to safety (5.45-5.47)	29
Requirement 30: Qualification of items important to safety (5.48-5.50)	30
Requirement 31: Ageing management (5.51-5.52)	30
Human factors	31
Requirement 32: Design for optimal operator performance (5.53-5.62)	31
Other design considerations	33
Requirement 33: Safety systems, and safety features for design extension conditions, of units of a multiple unit nuclear power plant (5.63)	33
Requirement 34: Systems containing flammable material or radioactive material	33
Requirement 35: Nuclear power plants used for cogeneration of heat and power, heat generation or desalination	33

Requirement 36: Escape routes from the plant (5.64-5.65)	33
Requirement 37: Communication systems at the plant (5.66-5.67)	34
Requirement 38: Control of access to the plant (5.68)	34
Requirement 39: Prevention of unauthorized access to, or interference with, items important to safety	34
Requirement 40: Prevention of harmful interactions of systems important to safety (5.69-5.70)	35
Requirement 41: Interactions between the electrical power grid and the plant	35
Safety analysis	35
Requirement 42: Safety analysis of the plant design (5.71-5.76)	35
DESIGN OF SPECIFIC PLANT SYSTEMS	
Reactor core and associated features	37
Requirement 43: Performance of fuel elements and assemblies (6.1-6.3)	37
Requirement 44: Structural capability of the reactor core	38
Requirement 45: Control of the reactor core (6.4-6.6)	38
Requirement 46: Reactor shutdown (6.7-6.12)	39
Reactor coolant systems	40
Requirement 47: Design of reactor coolant systems (6.13-6.16)	40
Requirement 48: Overpressure protection of the reactor coolant pressure boundary	41
Requirement 49: Inventory of reactor coolant	41
Requirement 50: Cleanup of reactor coolant (6.17)	41
Requirement 51: Removal of residual heat from the reactor core	41
Requirement 52: Emergency cooling of the reactor core (6.18-6.19)	42
Requirement 53: Heat transfer to an ultimate heat sink (6.19A-6.19B)	42
Containment structure and containment system	43
Requirement 54: Containment system for the reactor	43
Requirement 55: Control of radioactive release from the containment (6.20-6.21)	43
Requirement 56: Isolation of the containment (6.22-6.24)	43
Requirement 57: Access to the containment (6.25-6.26)	44
Requirement 58: Control of containment conditions (6.27-6.30)	45
Instrumentation and control systems	46


Requirement 59: Provision of instrumentation (6.31)	46
Requirement 60: Control systems	46
Requirement 61: Protection system (6.32-6.33)	46
Requirement 62: Reliability and testability of instrumentation and control systems (6.34-6.36)	47
Requirement 63: Use of computer based equipment in systems important to safety (6.37)	48
Requirement 64: Separation of protection systems and control systems (6.38)	48
Requirement 65: Control room (6.39-6.40A)	49
Requirement 66: Supplementary control room (6.41)	49
Requirement 67: Emergency response facilities on the site (6.42)	50
Emergency power supply	50
Requirement 68: Design for withstanding the loss of off-site power (6.43-6.45A)	50
Supporting systems and auxiliary systems	52
Requirement 69: Performance of supporting systems and auxiliary systems	52
Requirement 70: Heat transport systems (6.46)	52
Requirement 71: Process sampling systems and post-accident sampling systems (6.47)	52
Requirement 72: Compressed air systems	52
Requirement 73: Air conditioning systems and ventilation systems (6.48-6.49)	53
Requirement 74: Fire protection systems (6.50-6.54A)	53
Requirement 75: Lighting systems	54
Requirement 76: Overhead lifting equipment (6.55)	54
Other power conversion systems	55
Requirement 77: Steam supply system, feedwater system and turbine generators (6.56-6.58)	55
Treatment of radioactive effluents and radioactive waste	55
Requirement 78: Systems for treatment and control of waste (6.59-6.60)	55
Requirement 79: Systems for treatment and control of effluents (6.61-6.63)	56
Fuel handling and storage systems	56
Requirement 80: Fuel handling and storage systems (6.64-6.68A)	56
Radiation protection	59

Requirement 81: Design for radiation protection (6.69-6.76)	59
Requirement 82: Means of radiation monitoring (6.77-6.84)	60

- Requirement 5: Radiation Protection in Design
- Requirement 4: Fundamental Safety Functions
- Requirement 16: Postulated Initiating Events
- Requirement 13: Categories of Plant States
- Requirement 14: DB for items important to Safety
- Requirement 7: Application of Defence in Depth

control of reactivity

confinement



removal

heat

+Concept of Practical Elimination

22

Design safety Principal Technical Requirements & General plant design

6 'key' requirements 🖐️

Requirement 5: Radiation protection

The design of a NPP shall be such as to **ensure that radiation doses to workers at the plant and to members of the public:**

- do not exceed authorized limits and are kept as low as reasonably achievable in **normal operation and anticipated operational occurrences and during decommissioning**, and
- remain below acceptable limits **during and following accident conditions**.
- The design shall be such as to ensure that plant states that could lead to **high radiation doses or large radioactive releases are practically eliminated** and that there are no, or only minor, potential radiological consequences for plant states with a significant likelihood of occurrence.
- Acceptable limits for radiation protection associated with the relevant categories of plant states shall be established, consistent with the regulatory requirements.

Requirement 4: Fundamental safety functions (FSF)

Fulfilment of the following fundamental safety functions for a nuclear power plant shall be ensured for **all plant states**

- Control of **reactivity**
- **Removing heat** from the fuel
- **Confinement** of radioactive materials, shielding against radiation and control of operational discharges as well as limitation of accidental releases

A systematic approach shall be taken to identifying those **items important to safety** that are necessary to fulfil the FSFs functions and to identifying the inherent features that are contributing to fulfilling, or that are affecting the FSFs


Means of **monitoring the status of the plant** shall be provided for ensuring that the required safety functions are fulfilled.

An item that is part of a safety group and/or whose malfunction or failure could lead to radiation exposure of the site personnel or members of the public

Requirement 4: Fundamental safety functions (examples)


Control of reactivity

- Control rods
- Boron injection




Cooling of the core

- Steam generators
- Residual heat removal
- Safety injection



Confinement of radioactive materials

- Fuel cladding
- Primary cooling system
- Containment




Requirement 16: Postulated initiating events

Design shall apply a systematic approach to identifying a comprehensive set of postulated initiating events such that all foreseeable events with the potential for serious consequences and with a significant frequency of occurrence are anticipated and are considered in the design. PIEs shall:

- be identified using **engineering judgement** and a combination of **deterministic** and **probabilistic** considerations.
- include **all foreseeable failures of SSCs**, operating errors and failures arising from hazards
- cover **all operating states** (e.g. LPSD)
- be analysed to **establish the preventive measures and protective measures** that are necessary to ensure performance of the safety functions

Component, train, system	Failure mode	Effect
Fan 1V-36	Failure to operate	Decrease of V-36 vent system reliability
Fan 1V-36	Failure on demand	Decrease of V-36 vent system reliability
Fan 1V-36	Unavailability due to repair	Decrease of V-36 vent system reliability
...	...	...




Requirement 13: Categories of plant states

Plant states shall be identified and shall be grouped into a limited number of **categories according to their frequency of occurrence**

- Normal operation;
- Anticipated operational occurrences;
- Design basis accidents;
- Design extension conditions, including accidents with core melting.

Criteria shall be assigned to each plant state, such that **frequently occurring plant states shall have no, or only minor, radiological consequences** and plant states that could give rise to serious consequences shall have a very low frequency of occurrence.



Requirement 13: Categories of plant states

Frequency (f) range
Examples [per year]

Anticipated operational occurrence (AOO)

An operational process **deviating from normal operation** which is expected to occur **at least once during the operating lifetime** of a facility but which, in view of appropriate design provisions, **does not cause any significant damage to items important to safety or lead to accident conditions**.

$> 10^{-2}$

Design basis accident (DBA)

Accident conditions against which a facility is designed according to established design criteria, and for which the **damage to the fuel and the release of radioactive material are kept within authorized limits**.

10^{-2} - 10^{-4}


Design Extension Conditions (DECs)

Postulated accident conditions **that are not considered for design basis accidents**, but that are considered in the design process of the facility in accordance **with best estimate methodology, and for which releases of radioactive material are kept within acceptable limits**. DEC could include conditions without significant fuel degradation and conditions with core melting.

10^{-4} - 10^{-6} (*no core melt*)

10^{-6} $>$ (*with core melt*)

Requirement 13: Categories of plant states



Requirement 14: Design basis for items important to safety

The design of items important to safety shall specify the **necessary capability, reliability and functionality for the required plant operational states, for accident conditions and conditions generated by internal and external hazards, to meet the specified acceptance criteria for the lifetime of the plant.**

The design basis for each item important to safety shall be systematically justified and documented.

Design basis of the plant (e.g. it is a design basis accident) means in reality that the conditions generated due to a given accident are included in the design basis of a set of structures, systems and components (SSCs) that have the function to deal with and control that accident.

Requirement 14: Design basis for items important to safety

The design basis specifies for **each** structure, system and component (SSC) of the NPP:

- the **functions to be performed**, the operational states, accident conditions
- **conditions generated by internal and external hazards that SSC has to withstand**
- acceptance criteria for the **necessary capability, reliability, availability and functionality**
- specific assumptions and design rules

Plant Design Basis				
Operational states		Accident conditions		
NO	AOO	DBAs	Design Extension Conditions	
			Without significant fuel degradation	With core melting (severe accidents)
Loads and conditions generated by External & Internal Hazards (for each plant state)				
Criteria for functionality, capability, margins, layout and reliability (for each plant state)				
Design basis of equipment for Operational states		Design Basis of Safety Systems including SSCs necessary to control DBAs and some AOOs	Design Basis of safety features for <u>DECs</u> including SSCs necessary to control DECs	
			Features to prevent core melt	Features to mitigate core melt (Containment systems)

Requirement 7: Application of defence in depth

From SF-1, principle 8

The primary means of preventing and mitigating the consequences of accidents is 'defence in depth'.

The design of a nuclear power plant shall incorporate defence in depth. The levels of defence in depth shall be independent as far as is practicable.



- The existence of multiple levels of defence is not a basis for continued operation in the absence of one level of defence. All levels of defence in depth shall be kept available at all times.
- Relaxations shall be justified for specific modes of operation

Requirement 7: Application of defence in depth

The design shall

- provide for multiple physical barriers to the release of radioactive material;
- be conservative, and the construction shall be of high quality, so as to minimize failures, prevent accidents as far as is practicable and avoid cliff edge effects;
- provide for the control of plant behaviour by means of inherent and engineered features, such that failures and deviations from normal operation requiring actuation of safety systems are minimized or excluded by design, to the extent possible;
- provide for supplementing the control of the plant by means of automatic actuation of safety systems, such that failures can be controlled with a high level of confidence, and the need for operator actions in an early phase is minimized;
- provide for SSCs and procedures to control the course of and, as far as practicable, to limit the consequences of failures and deviations from normal operation that exceed the capability of safety systems;
- provide multiple means for ensuring that each of the fundamental safety functions is performed, thereby ensuring the effectiveness of the barriers

Requirement 7: Application of defence in depth



Requirement 7: Application of defence in depth

- The design shall be such as to ensure, as far as is practicable, that the first, or at most the second, level of defence is capable of **preventing an escalation to accident conditions for all failures or deviations from normal operation** that are likely to occur over the operating lifetime of the nuclear power plant.
- The levels of defence in depth shall be independent as far as practicable to avoid a failure of one level reducing the effectiveness of other levels. In particular, safety features for design extension conditions (especially features for mitigating the consequences of accidents involving the melting of fuel) shall be as far as is practicable independent of safety systems.

Practical elimination

SSR-2/1 (Rev. 1), Par 2.13 (4)

“The safety objective in the case of a severe accident is that only protective actions that are limited in terms of lengths of time and areas of application would be necessary and that off-site contamination would be avoided or minimized. Event sequences that would lead to an **early radioactive release** or a **large radioactive release** are required to be ‘**practically eliminated**’”

Radioactive release for which off-site protective actions would be **necessary** but would be **unlikely** to be **fully effective** in due time

Radioactive release for which off-site protective actions that are **limited in terms of lengths** of time and areas of application would be **insufficient** for the protection of people and of the environment

It would be **physically impossible** for the conditions to **arise** or if these conditions could be considered with a **high level of confidence to be extremely unlikely to arise**

Design safety Principal Technical Requirements & General plant design

Other important requirements 🧐

Contents of Design Requirements (SSR 2/1)



INTRODUCTION

APPLYING SAFETY PRINCIPLES AND CONCEPTS

MANAGEMENT OF SAFETY IN DESIGN

- 3 Requirements

PRINCIPAL TECHNICAL REQUIREMENTS

- 9 Requirements

GENERAL PLANT DESIGN

- Design Basis (16 Requirements)
- Safe Operation Over Lifetime of Plant (3 Requirements)
- Human Factors (1 Requirement)
- Other Design Considerations (9 Requirements)
- Safety Analysis (1 Requirement)

DESIGN OF SPECIFIC PLANT SYSTEMS

- Reactor Core and Associated Features (4 Requirements)
- Reactor Coolant Systems (7 Requirements)
- Containment Structure and Containment System (5 Requirements)
- Instrumentation and Control Systems (9 Requirements)
- Emergency Power Supply (1 Requirement)
- Supporting Systems and Auxiliary Systems (8 Requirements)
- Other Power Conversion Systems (1 Requirement)
- Treatment of Radiological Effluents and Radioactive Waste (2 Requirements)
- Fuel Handling and Storage System (1 Requirement)
- Radiation Protection (2 Requirements)

Requirements 22: Safety classification

All items important to safety shall be identified and shall be classified on the basis of their function and their safety significance.

The method for classification shall be based primarily on deterministic methods complemented, where appropriate, by probabilistic methods, taking into account factors e.g.:

- **Safety function (SF)** to be performed by the item
- **Consequences** of failure to perform a SF;
- **Frequency** with which the item will be called upon to perform a safety function;
- **Time** following a postulated initiating event at which, or the period for which, the item will be called upon to perform a safety function.

TABLE 1. RELATIONSHIP BETWEEN FUNCTIONS CREDITED IN THE ANALYSIS OF POSTULATED INITIATING EVENTS AND SAFETY CATEGORIES

Functions credited in the safety assessment	Severity of the consequences if the function is not performed		
	High	Medium	Low
Functions to reach a controlled state after anticipated operational occurrences AOO	Safety category 1	Safety category 2	Safety category 3
Functions to reach a controlled state after design basis accidents DBA	Safety category 1	Safety category 2	Safety category 3
Functions to reach and maintain a safe state	Safety category 2	Safety category 3	Safety category 3
Functions for the mitigation of consequences of design extension conditions DEC	Safety category 2 or 3 (see para. 3.15)	Not categorized ^a	Not categorized ^a

^a Medium or low severity consequences are not expected to occur in the event of non-response of a dedicated function for the mitigation of design extension conditions.

Requirement 9: Proven engineering practices

Items important to safety for a nuclear power plant shall be designed in accordance with the relevant national and international codes and standards.

- Items important to safety shall preferably be of a design that has **previously been proven**
- If not, shall be items of **high quality and of a technology** (qualified and tested)
- **If unproven design or feature is introduced** or if there is a departure from an established engineering practice, safety shall be demonstrated by means of
 - appropriate supporting research programmes,
 - performance tests with specific acceptance criteria
 - examination of operating experience from other relevant applications
 - monitor in service to verify the behaviour is as expected



Requirement 17: Internal and external hazards

- All foreseeable **internal hazards and external hazards**, including the potential for human induced events to affect the safety of NPP, shall be identified and their effects shall be evaluated.
- Hazards shall be considered in designing the layout of the plant and in **determining the PIEs and generated loadings** for use in the design of relevant items important to safety for the plant.
- Items important to safety shall be designed and located **to withstand the effects of hazards or to be protected, in accordance with their importance to safety**, against hazards and against common cause failure mechanisms generated by hazards.
- For **multiple unit plant sites**, the design shall take due account of the potential for specific hazards to give rise to impacts on several or even all units on the site simultaneously.


Requirement 17: Internal and external hazards

Internal hazards

- Fire
- Explosion
- Flooding
- Missile generation
- Collapse of structures and falling objects
- Pipe whip
- Jet impact
- Release of fluid from failed systems or from other installations on the site

External hazards

- Natural
 - Earthquake
 - Tsunami
 - Volcano eruption
 - Flooding
 - Extreme weather conditions
 - ...
- Human induced
 - Aircraft impact
 - Explosions
 - Fire
 - Release of Hazardous Substances
 - ...




Requirements 21: Physical separation and independence of safety systems

Interference between safety systems or between redundant elements of a system shall be prevented by means such as

- physical separation,
- electrical isolation,
- functional independence
- independence of communication (data transfer)

as appropriate.



Requirement 10: Safety Assessment

- Comprehensive **deterministic safety assessments** and **probabilistic safety assessments** shall be carried out throughout the design process for a nuclear power plant to ensure that all safety requirements on the design of the plant are met throughout all stages of the lifetime of the plant, and to confirm that the design, as delivered, meets requirements for manufacture and for construction, and as built, as operated and as modified.
- The safety assessments shall be commenced at an **early point in the design process**, with iterations between design activities and confirmatory analytical activities, and shall increase in scope and level of detail as the design programme progresses.
- The safety assessments shall be documented in a form that facilitates **independent evaluation**.

Requirement 42: Safety analysis of the plant design

A safety analysis of the design for the NPP shall be conducted in which methods of **both deterministic analysis and probabilistic analysis shall be applied** to enable the challenges to safety in the various plant states to be assessed.

The safety analysis shall provide assurance that:

- **design basis are confirmed** for items important to safety and their links to initiating events and event sequences
- NPP is capable of complying with **authorized limits on discharges with regard to radioactive releases and with the dose limits in all operational states**
- NPP is capable of meeting **acceptable limits for accident conditions**.
- DiD has been implemented
- uncertainties adequately considered and adequate margins are available to **avoid cliff edge effects** and **early radioactive releases or large radioactive releases**.
- analytical assumptions, methods and degree of conservatism used in the design of the plant shall be updated and verified for the current or as built design.

Requirement 8: 3S interfaces

Requirement 8: Interfaces of safety with security and safeguards

Safety measures, nuclear security measures and arrangements for the State system of accounting for, and control of, nuclear material for a nuclear power plant shall be designed and implemented in an integrated manner so that they do not compromise one another.

- **There are interfaces** between 3S (conflicts, potential synergies)
- Interfaces are currently **not considered systematically**
- **Hard to address** (or impossible) when design is finalized
- **Unique time window** while the reactors are in design stage
- **Getting more complex** in light of the innovative reactors, e.g. SMRs (novelties lead to several challenges for all 3S)


IAEA Safety Standards
for protecting people and the environment

Safety of
Nuclear Power Plants:
Design

Specific Safety Requirements
No. SSR-2/1 (Rev. 1)



Requirement 8: 3S interfaces




How the design process
goes in reality

☺ **Joking!**

© *Slide created by Ross Peel*
(Imperial College, UK), was presented
at IAEA TM on 3S (1-3 June 2022)




Requirement 8: 3S interfaces



Applicability to non- water cooled reactors and SMRs

IAEA SSR-2/1(Rev.1): Applicability

- **Example from SSR-2/1(Rev.1) Scope**
 - 1.6. It is expected that this publication will be used primarily for land based stationary nuclear power plants with water cooled reactors designed for electricity generation or for other heat production applications (such as district heating or desalination). This publication may also be applied, with judgement, to other reactor types, to determine the requirements that have to be considered in developing the design.



Safety Guides for the Design of NPPs


Design Safety















Safety objectives and safety principles



Functional conditions required for safety



Guidance on how to fulfil the requirements



Concluding remarks

The IAEA Specific Safety Requirements – Safety of Nuclear Power Plants: Design SSR-2/1 (Rev. 1)

- **Reflects the international consensus** on what constitutes a high level of safety that can reasonably be achieved in the design of nuclear power plants, to meet the fundamental safety objective and in compliance with the ten safety principles
- **Contains 82 requirements:** Management of safety in design, Principal technical requirements, General plant design requirements, Design of specific plant systems
- **Key set of requirements** to for the design of the NPP
- **Supported by numerous Safety Guides:** e.g. system specific (reactor core, I&C)
- **Next revision of SSR-2/1(Rev.1)** has been just initiated in March 2025




Thank you!

Safety-Standards.Contact-Point@iaea.org

Annex

IAEA SSG-30: Safety Classification

plant equipment (for a nuclear power plant)



^a In this context, an 'item' is a structure, system or component.

IAEA Safety Standards

for protecting people and the environment

Safety Classification of Structures, Systems and Components in Nuclear Power Plants

Specific Safety Guide

No. SSG-30



IAEA
International Atomic Energy Agency

IAEA SSG-34: Electrical Power Systems

Preferred power supply:

The power supply from the transmission system to the safety classified electrical power system

Important to safety power supply:


The power supply to internal safety buses

Safety power system:

The standby AC power source with associated safety buses

Alternate AC power system:

A power source reserved for the use for the power supply to the plant during total loss of all non-battery power in the safety power systems (station blackout) and other design extension conditions



IAEA Safety Standards
for protecting people and the environment

Design of Electrical
Power Systems for
Nuclear Power Plants

Specific Safety Guide
No. SSG-34



IAEA SSG-38: Construction



IAEA Safety Standards

for protecting people and the environment

Construction for
Nuclear Installations


Specific Safety Guide

No. SSG-38



IAEA
International Atomic Energy Agency

IAEA SSG-39: Instrumentation and Control Systems



IAEA Safety Standards

for protecting people and the environment

Design of Instrumentation and Control Systems for Nuclear Power Plants


Specific Safety Guide

No. SSG-39



IAEA
International Atomic Energy Agency

IAEA SSG-51: Human Factors Engineering



IAEA Safety Standards

for protecting people and the environment

Human Factors Engineering in the Design of Nuclear Power Plants

Specific Safety Guide

No. SSG-51



IAEA
International Atomic Energy Agency

IAEA SSG-52: Reactor Core



IAEA Safety Standards
for protecting people and the environment

Design of the
Reactor Core for
Nuclear Power Plants

Specific Safety Guide
No. SSG-52



IAEA SSG-52: Reactor Containment and Associated Systems



IAEA Safety Standards

for protecting people and the environment

Design of the Reactor
Containment and
Associated Systems for
Nuclear Power Plants


Specific Safety Guide

No. SSG-53



IAEA
International Atomic Energy Agency

IAEA SSG-52: Reactor Coolant System and Associated Systems



IAEA Safety Standards

for protecting people and the environment

Design of the Reactor
Coolant System and
Associated Systems for
Nuclear Power Plants

Specific Safety Guide

No. SSG-56



IAEA

International Atomic Energy Agency

IAEA SSG-62: Auxiliary Systems and Supporting Systems

4.	SPECIFIC CONSIDERATIONS IN DESIGN (4.1–4.4)	20
	Communication systems (4.5–4.24)	20
	Heat transport systems (4.25–4.44)	24
	Process and post-accident sampling system (4.45–4.72)	28
	Process radiation monitoring system (4.73–4.93)	33
	Compressed air system (4.94–4.107)	36
	Heating, ventilation and air-conditioning systems (4.108–4.170)	38
	Lighting and emergency lighting systems (4.171–4.179)	50
	Overhead lifting equipment (4.180–4.198)	52
	Systems for treatment and control of radioactive waste and radioactive effluents (4.199–4.232)	55
	Supporting systems for the emergency power supply and the alternate power source (4.233–4.267)	62
	Other systems (4.268–4.289)	68

IAEA Safety Standards

for protecting people and the environment

Design of Auxiliary Systems
and Supporting Systems for
Nuclear Power Plants


Specific Safety Guide

No. SSG-62



IAEA
International Atomic Energy Agency

IAEA SSG-63: Fuel Handling and Storage Systems



IAEA Safety Standards

for protecting people and the environment

Design of
Fuel Handling and
Storage Systems for
Nuclear Power Plants

Specific Safety Guide

No. SSG-63



IAEA
International Atomic Energy Agency

IAEA SSG-64: Protection against Internal Hazards

4.	RECOMMENDATIONS FOR SPECIFIC INTERNAL HAZARDS	12
	Internal fires (4.1–4.59)	12
	Internal explosions (4.60–4.77)	24
	Internal missiles (4.78–4.109)	28
	Pipe breaks (pipe whip and jet effect and flooding) (4.110–4.144) ...	35
	Internal flooding (4.145–4.172)	42
	Heavy load drop (4.173–4.186)	47
	Electromagnetic interference (4.187–4.200)	50
	Release of hazardous substances inside the plant (4.201–4.216)	53

IAEA Safety Standards

for protecting people and the environment

Protection against Internal Hazards in the Design of Nuclear Power Plants


Specific Safety Guide

No. SSG-64



IAEA
International Atomic Energy Agency

IAEA SSG-69: Equipment Qualification



IAEA Safety Standards

for protecting people and the environment

Equipment Qualification for Nuclear Installations


Specific Safety Guide

No. SSG-69



IAEA
International Atomic Energy Agency

IAEA SSG-88: Equipment Qualification



IAEA Safety Standards

for protecting people and the environment

Design Extension Conditions
and the Concept of
Practical Elimination
in the Design of
Nuclear Power Plants

Specific Safety Guide

No. SSG-88



IAEA
International Atomic Energy Agency

IAEA SSG-90: Radiation Protection

	Design targets		Optimization process	Dose rates		Individual and collective doses
Item Step	Individual dose target	Collective dose target	Studies to be performed	Zoning	Contact dose rate	Exposed work volume
Step 1	Average for all workers	Total for facility	Description of advantages/ drawbacks of options	(Not relevant)	(Not relevant)	Estimation of exposed work volume with options
Step 2	Update Step 1 value	Update Step 1 value	Evaluate main options	Establish approximate zoning	(Not relevant)	Programme definition of exposed work volume estimation
Step 3	Definitive value for the average for all workers	Evaluation with decisions of Step 2	Limited to important points	Evaluate using design source term/realistic source term/accident source term	Calculate contact dose rates	Estimation of exposed work volume
Step 4	Values for each task type	Evolution	Detailed by tasks	Verification/ precision	Verification/ precision	Detailed evaluation of exposed work volume

